

1.0 Scope and Application.

Method 5 - Determination Of Particulate Matter Emissions From Stationary Sources

NOTE: This method does not include all of the specifications (e.g., equipment and [supplies](#)) and procedures (

applicable subpart of the standards or as approved by the Administrator for a particular application. Since

A Temperature Sensor capable of measuring temperature to within ± 3 °C (5.4 °F) shall be installed so that the sensing tip of the Temperature Sensor is in direct contact with the sample gas, and the temperature around the filter holder can be regulated and monitored during sampling.

6.1.1.8 Condenser.

The following system shall be used to determine the stack gas moisture content: Four impingers

of isokinetic and of determining sample volumes to within 2 percent may be used, subject to the approval of the Administrator. When the metering system is used in conjunction with a pitot tube, allow periodic checks of isokinetic rates.

8.1.2 Check filters

taken (corrected to standard conditions) will exceed the required minimum total gas sample volume. The latter is based on an approximate average sampling rate.

8.2.5 The sampling time (e) -0.4 () -0.2 (a) 0.1 (t) -0.2 () -0.2 (e) -0.4 (a) 0.1 (c) -0.1(h) -0.2 (p) -0.3 (o) sampled at each point be an integer or an integer plus one-half minute, in order to avoid timekeeping errors.


8.2.6 10.4 (-ha) -0.2 (s)-0.1 (o) -0.1 (mn) 0.2 e circumnta0.4 (-hac) -0.1 (e) -0.4 (s) -0.1 () -0.2(()] TJ ET Q

8.4 Leak-Check Procedures.

8.4.1 Leak Check of metering System Shown in Figure 5-1.

That portion of the Sampling train from the pump to the orifice meter should be leak-checked prior to initial use and after each shipment. Leakage after the pump will result in less volume being received or is a partially sampled. The following procedure is suggested (see

calibration check value, Y_c , as follows:



where:

Y_c = DGM calibration check value, dimensionless.

t = Run time, min.

9.2.1.2 Compare the Y_c

hours of desiccation time between weighings. Alternatively, the sample may be oven dried at 104 °C (220 °F) for 2 to 3 hours, cooled in the desiccator, and weighed to a constant weight, unless otherwise specified by the Administrator. The sample may be oven dried at 104 °C (220 °F) for 2 to 3 hours. Once the sample has cooled, weigh the sample, and use this weight as a final weight.

11.2.2 Container No. 2.

Note the level of liquid in the container, and confirm on the analysis sheet whether leakage occurred during transport. If a noticeable amount of leakage has occurred, either void the sample or use methods, subject to the approval of the Administrator, to correct the final results. Measure the liquid in this container either volumetrically to ± 1 ml or gravimetrically to ± 0.5 g. Transfer the contents to a tared 250 ml beaker, and evaporate to dryness at ambient temperature and pressure. Desiccate for 24 hours, and weigh to a constant weight. Report the results to the nearest 0.1 mg.


11.2.3 Container No. 3.

Weigh the spent silica gel (or silica gel plus impinger) to the nearest 0.5 g using a balance. This step may

C_a = Acetone blank residue concentration, mg/mg.

C_s =





T_w = Average wet test meter temperature, °C (°F)

P_{bar} = Barometric pressure, mm Hg (in. Hg).

" p = console meter inlet differential pressure, mm H₂O (in. H₂O).

= Run time, min.

12.1.1.5 Compare the three Y_{ds} values at each of the flow rates and determine the maximum and minimum values. The difference between the maximum and minimum value at each flow rate should be no greater than 0.030. Extra sets of triplicate runs may be made in order to complete this requirement. In addition, the meter coefficients should be between 0.95 and 1.05. If these specifications cannot be met in three sets of successive triplicate runs, the meter is not suitable as a calibration standard and should not be used. If these specifications are met, average the three Y_{ds} values at each flow rate resulting in five average meter coefficients, Y_{ds} .

16.2.2. Record the information listed in Figure 5-12.

16.2.3.3 Calculate the standard volumes of air passed through the DGM and the critical orifices, and

TABLE 5-1. FLOW RATES FOR VARIOUS NEEDLE SIZES AND SUBS.

Needle Size	Flow Rate	
	Gallons per Minute	Litres per Minute
13/7.6	2.18	8.27
13/10.2	20.67	78.4

Figure 5-1. Particulate Sampling train.





Figure 5-2. Leak Check of meter Box.

Blank	Date	
Run No.		
Printer No.		
Amount liquid lost during		
Acetone		
Container	Weight	Initial weight
1.		
2.		
Total		
Initial weight acetone blank		
Weight of particulate matter		
Volume		
Impinger volume		
Final.....		
Total volume		
CG		
Convert weight of water to volume by dividing total increase by density of water (1 g/ml)		
Increase, g	Volume water	
(1g/ml)		

Figure 5-7. equipment Arrangement for console meter calibration.






Figure 5-11. Data sheet for determining K' factor.

Date		_____	
Time		_____	
DGM cal		_____	
Critical orifice ID		_____	
Dry gas	Run number	1	2
Final reading, Q_{12}	m^3 (ft ³)
Initial reading, Q_{11}	m^3 (ft ³)
Volume, V	m^3 (ft ³)
Inlet, outlet	temperature
Initial
Final
Avg. area
t_1
Orifice man. rdg., K	mm (in.) H ₂ O
Barometric pressure	mm (in.) Hg
Ambient temperature
t_{amb}
K' factor
Average

